

TÜV Rheinland Immissionsschutz und Energiesysteme GmbH
D-51101 Köln

Centrosolar AG
Mr Mirko Held
Behringstr. 16
22765 Hamburg

Herbert Becker
Phone ++49-221/806-2476
Fax ++49-221/806-1350
Mail enertest@de.tuv.com
Web www.tuv.com
www.tuv-pv-cert.de
25 November 2008

**Declaration
- 21209996-1e -**

Manufacturer: Centrosolar AG
Behringstr. 16
22765 Hamburg
Germany

Product: PV-Modules
Type: **Biosol P1170**
Biosol P1180
Biosol P1190
Biosol PIL190
Biosol MIL190
Biosol MIL200


Herewith it is declared that the above mentioned PV-Modules have successfully passed all laboratory test to obtain qualification according to IEC 61215:2005 and IEC 61730:2004 qualification testing. A certificate will soon be issued.
The above listed PV modules fulfil the requirements of Application Class A (Safety Class II). They may be used in PV plants at a maximum system voltage (Voc at STC) of up to **1000 VDC**.

Renewable Energies

i. V.


Dipl.-Ing. W. Vaaßen

i. A.


Dipl.-Ing. H. Becker

TÜV Rheinland
Immissionsschutz und
Energiesysteme GmbH

Am Grauen Stein
D – 51105 Cologne, Germany

Tel. ++49-221/806-2477
Fax ++49-221/806-1350
Mail enertest@de.tuv.com
Web www.umwelt-tuv.de

Managing Director
Dr.-Ing. Wolfgang Jockel

Amtsgericht Köln HRB 32190